

## CHAPTER 20

# EMERGENCY NOTIFICATION, ACCESS AND FACILITIES

### SECTION 2001 EMERGENCY NOTIFICATION, ACCESS AND FACILITIES

#### 2001.1 Objectives.

**2001.1.1 Notification, access and facilities for emergency responders.** To provide and maintain means of notification, access and facilities for emergency operations and responders.

**2001.1.2 Notification for life safety and property protection.** To provide notification of the need to take some manual action to preserve the safety of occupants or to limit property damage.

**2001.2 Functional statements.** As appropriate to the design performance level in Chapter 3, the following shall be addressed:

1. Provide and maintain appropriate access for emergency vehicles.
2. Provide and maintain appropriate access for emergency responders.
3. Provide and maintain necessary staging, command and control areas, support facilities and equipment for emergency operations.
4. Provide sufficient, reliable water for fire-fighting operations.
5. Provide and maintain appropriate means of promptly notifying emergency responders.
6. Where required, provide and maintain adequate means of occupant notification to warn of the presence of a fire or other emergency in sufficient time to enable occupants to take the contemplated action without being exposed to unreasonable risk of injury or death.

#### 2001.3 Performance requirements.

**2001.3.1 Vertical and horizontal clearance for fire department apparatus.** Vertical and horizontal clearance shall permit the unimpeded access of fire department apparatus inclusive of the capability for one apparatus to pass another apparatus set up and in operation.

**2001.3.2 Protrusions and appurtenances from structures.** Protrusions and appurtenances from structures shall not impede access, including vertical access, to the height of fire department aerial apparatus.

**2001.3.3 Surfaces for fire department apparatus.** Fire department access shall be on surfaces permitting year-round, all-weather travel at a grade appropriate for the fire apparatus.

**2001.3.4 Hose length limitations.** Access to structures shall afford the fire department the ability to deploy and

operate hose lines without the need to extend the standard hose line utilized by the fire department having jurisdiction.

**2001.3.5 Control valve locations.** Within structures, means for the deployment and operation of hose lines by emergency responders shall be provided such that control valves for lines shall be no further from potential fire sources than the length of hose packs employed by a single engine company of the fire department having jurisdiction.

**2001.3.6 Water supply.** Water supply for fire department operations shall be from a reliable, readily accessible source acceptable to the fire department and capable of supporting fire-fighting operations.

**2001.3.7 Horizontal or vertical conveyance.** Means of horizontal or vertical conveyance shall be provided where necessary to support fire-fighting and emergency support functions.

**2001.3.8 Staging areas.** Where interior operations may be necessary, areas to stage equipment and from which to safely conduct and to control suppression operations shall be provided.

**2001.3.9 Interaction of access and means of egress.** Exterior and interior egress and emergency access shall be arranged and maintained so that building occupants and emergency responders are unimpeded as each accomplishes its objectives of egress of occupants and access by emergency responders.

**2001.3.10 Interior and exterior staging.** When necessary to ensure timely and effective emergency operations, interior or exterior areas shall be provided for the staging of equipment and apparatus.

**2001.3.11 On-site equipment.** When necessary to ensure timely and effective emergency operations, fire-fighting equipment or other equipment to support such operations shall be provided and maintained readily available for use by emergency responders.

**2001.3.12 Notification requirements.** Where systems are designed to notify the emergency-response agency of the need to respond to an emergency, such system shall indicate the type of emergency and the location of the building, premises or facility. Where such buildings, premises or facilities are large enough that difficulty is expected in promptly locating the emergency, identification of the area or zone of the emergency shall be provided at the building, premises or facilities.

**2001.3.13 Notification of occupants.** Notification of occupants shall be by means appropriate to the needs of the occupants, the use of the building and the emergency egress strategy employed.

