

## CHAPTER 2

# DEFINITIONS

### SECTION 201 GENERAL

**201.1 Scope.** Unless otherwise expressly stated, the following words and terms shall, for the purposes of this code, have the meanings shown in this chapter.

**201.2 Interchangeability.** Words used in the present tense include the future; words stated in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural, the singular.

**201.3 Terms defined in other codes.** Where terms are not defined in this code and are defined in the *International Building Code*, *International Mechanical Code*, *National Electrical Code* or *Arizona State Plumbing Code*, such terms shall have the meanings ascribed to them as in those codes.

**201.4 Terms not defined.** Where terms are not defined through the methods authorized by this section, such terms shall have ordinarily accepted meanings such as the context implies. *Webster's Third New International Dictionary of the English Language, Unabridged*, shall be considered as providing ordinarily accepted meanings.

### SECTION 202 GENERAL DEFINITIONS

[B] **ACCESSIBLE MEANS OF EGRESS.** See Section 1002.1.

|| **ADDRESS DIRECTORIES.** See Section 502.

**AEROSOL.** See Section 2802.1.

**Level 1 aerosol products.** See Section 2802.1.

**Level 2 aerosol products.** See Section 2802.1.

**Level 3 aerosol products.** See Section 2802.1.

**AEROSOL CONTAINER.** See Section 2802.1.

**AEROSOL WAREHOUSE.** See Section 2802.1.

**AGENT.** A person who shall have charge, care or control of any structure as owner, or agent of the owner, or as executor, executrix, administrator, administratrix, trustee or guardian of the estate of the owner. Any such person representing the actual owner shall be bound to comply with the provisions of this code to the same extent as if that person was the owner.

**AIRCRAFT OPERATION AREA (AOA).** See Section 1102.1.

**AIRPORT.** See Section 1102.1.

[B] **AISLE ACCESSWAY.** See Section 1002.1.

**ALARM NOTIFICATION APPLIANCE.** See Section 902.1.

**ALARM SIGNAL.** See Section 902.1.

**ALARM VERIFICATION FEATURE.** See Section 902.1.

**ALTER OR ALTERATION.** A change, addition or modification in construction or occupancy. ||

[B] **ALTERNATING TREAD DEVICE.** See Section 1002.1.

**ALTERNATIVE SURFACE ACCESS ROADS.** See Section 502. ||

**AMMONIUM NITRATE.** See Section 3302.1.

**AMUSEMENT BUILDING, SPECIAL.** See "Special Amusement Building."

**ANNUNCIATOR.** See Section 902.1.

**APPROVED.** Refers to approval by the chief as the result of review, investigation or tests conducted by the chief or the reason of accepted principals or tests by national authorities, or technical or scientific organizations. ||

[B] **AREA OF REFUGE.** See Section 1002.1.

**ARRAY.** See Section 2302.1.

**ARRAY, CLOSED.** See Section 2302.1.

**AUDIBLE ALARM NOTIFICATION APPLIANCE.** See Section 902.1.

**AUTOMATIC.** See Section 902.1.

**AUTOMATIC FIRE-EXTINGUISHING SYSTEM.** See Section 902.1.

**AUTOMATIC SPRINKLER SYSTEM.** See Section 902.1.

**AUTOMOTIVE MOTOR FUEL-DISPENSING FACILITY.** See Section 2202.1.

**AUXILIARY ACCESS OPENINGS.** See Section 502. ||

**AVERAGE AMBIENT SOUND LEVEL.** See Section 902.1.

**BANDING.** Banding is a method of packaging consisting of stretch wrapping around only the sides of a pallet load. ||

**BARRICADE.** See Section 3302.1.

**Artificial barricade.** See Section 3302.1.

**Natural barricade.** See Section 3302.1.

**BARRICADED.** See Section 3302.1.

**BATTERY, LEAD ACID.** See Section 602.1.

**BATTERY SYSTEM, STATIONARY LEAD ACID.** See Section 602.1.

**BIN BOX.** See Section 2302.1.

**BLAST AREA.** See Section 3302.1.

**BLAST SITE.** See Section 3302.1.

**BLASTER.** See Section 3302.1.

**BLASTING AGENT.** See Section 3302.1.

**BOILING POINT.** See Section 2702.1.

**BONFIRE.** See Section 302.1.

## DEFINITIONS

**BREATHING AIR.** Oxygen or a respirable gas mixture stored in a compressed state and supplied to the user in gaseous form. It is a minimum air quality of Grade D as specified in ANSI/CGA G-7.1, *Commodity Specifications for Air*, and shall have a water content not exceeding 24 parts per million by volume and shall have a maximum particulate level of 5 milligram per cubic meter in air.

**BRITISH THERMAL UNIT (BTU).** The heat necessary to raise the temperature of 1 pound (0.454 kg) of water by 1°F (0.5565°C).

**BUILDING OFFICIAL.** The officer or other designated authority of the jurisdiction charged with the administration and enforcement of the Building Code, or the building official's duly authorized representative.

**BULK OXYGEN SYSTEM.** See Section 4002.1.

**BULK PLANT OR TERMINAL.** See Section 3402.1.

**BULK TRANSFER.** See Section 3402.1.

**BULLET RESISTANT.** See Section 3302.1.

**CANOPY.** See Section 2402.1.

**CARBON DIOXIDE EXTINGUISHING SYSTEM.** See Section 902.1.

**CARTON.** A cardboard or fiberboard box enclosing a product.

**CEILING LIMIT.** See Section 2702.1.

**CHEMICAL.** See Section 2702.1.

**CHEMICAL NAME.** See Section 2702.1.

**CLEAN AGENT.** See Section 902.1.

**CLOSED CONTAINER.** See Section 2702.1.

**CLOSED SYSTEM.** The use of a solid or liquid hazardous material involving a closed vessel or system that remains closed during normal operations where vapors emitted by the product are not liberated outside of the vessel or system and the product is not exposed to the atmosphere during normal operations; and all uses of compressed gases. Examples of closed systems for solids and liquids include product conveyed through a piping system into a closed vessel, system or piece of equipment.

**CODE ENFORCEMENT AGENCY.** The City of Phoenix, Arizona, Fire Department.

**COLD DECK.** See Section 1902.1.

**COMBUSTIBLE DUST.** See Section 1302.1.

**COMBUSTIBLE FIBERS.** See Section 2902.1.

**COMBUSTIBLE LIQUID.** See Section 3402.1.

**Class II.** See Section 3402.1.

**Class IIIA.** See Section 3402.1.

**Class IIIB.** See Section 3402.1.

**[M] COMMERCIAL COOKING APPLIANCES.** See Section 602.1.

**COMMODITY.** See Section 2302.1.

**[B] COMMON PATH OF EGRESS TRAVEL.** See Section 1002.1.

**COMPRESSED GAS.** See Section 3002.1.

**COMPRESSED GAS CONTAINER.** See Section 3002.1.

**COMPRESSED GAS SYSTEM.** See Section 3002.1.

**CONSTANTLY ATTENDED LOCATION.** See Section 902.1.

**CONSTRUCTION DOCUMENTS.** The written, graphic and pictorial documents prepared or assembled for describing the design, location and physical characteristics of the elements of the project necessary for obtaining a permit.

**CONTAINER.** See Section 2702.1.

**CONTAINMENT SYSTEM.** See Section 3702.1.

**CONTAINMENT VESSEL.** See Section 3702.1.

**CONTINUOUS GAS DETECTION SYSTEM.** See Section 1802.1.

**CONTROL AREA.** See Section 2702.1.

**[B] CORRIDOR.** See Section 1002.1.

**CORROSIVE.** See Section 3102.1.

**CRYOGENIC CONTAINER.** See Section 3202.1.

**CRYOGENIC FLUID.** See Section 3202.1.

**CRYOGENIC VESSEL.** See Section 3202.1.

**CYLINDER.** See Section 2702.1.

**DAY BOX.** See Section 2702.1.

**DEFLAGRATION.** See Section 2702.1.

**DELUGE SYSTEM.** See Section 902.1.

**DESIGN PRESSURE.** See Section 2702.1.

**DETACHED BUILDING.** See Section 2702.1.

**DETEARING.** See Section 1502.1.

**DETECTOR, HEAT.** See Section 902.1.

**DETONATING CORD.** See Section 3302.1.

**DETONATION.** See Section 3302.1.

**DETONATOR.** See Section 3302.1.

**DIP TANK.** See Section 1502.1.

**DISCHARGE SITE.** See Section 3302.1.

**DISPENSING.** See Section 2702.1.

**DISPENSING DEVICE, OVERHEAD TYPE.** See Section 2202.1.

**DISPLAY SITE.** See Section 3302.1.

**[B] DOOR, BALANCED.** See Section 1002.1.

**DRAFT CURTAIN.** See Section 2302.1.

**DRY-CHEMICAL EXTINGUISHING AGENT.** See Section 902.1.

**DRY CLEANING.** See Section 1202.1.

**DRY CLEANING PLANT.** See Section 1202.1.

**DRY CLEANING ROOM.** See Section 1202.1.

**DRY CLEANING SYSTEM.** See Section 1202.1.

**EARLY SUPPRESSION FAST-RESPONSE (ESFR) SPRINKLER.** See Section 2302.1.

**[B] EGRESS COURT.** See Section 1002.1.

**ELECTROSTATIC FLUIDIZED BED.** See Section 1502.1.

**EMERGENCY.** An event or set of circumstances demanding immediate attention and remediation.

**EMERGENCY ALARM SYSTEM.** See Section 902.1.

**EMERGENCY CONTROL STATION.** See Section 1802.1.

**[B] EMERGENCY ESCAPE AND RESCUE OPENING.** See Section 1002.1.

**EMERGENCY EVACUATION DRILL.** See Section 402.1.

**EMERGENCY POWER SYSTEM.** An electrical system where the current supply is designed such that in the event of interruption of the normal power supply, a second source of adequate capacity and rating is available within 10 seconds of power failure.

**EMERGENCY SHUTOFF VALVE.** A valve designed to shut off the flow of gases or liquids.

**EMERGENCY SHUTOFF VALVE, AUTOMATIC.** A fail-safe automatic-closing valve designed to shut off the flow of gases or liquids, initiated by a control system that is activated by automatic means.

**EMERGENCY SHUTOFF VALVE, MANUAL.** A manually operated valve designed to shut off the flow of gases or liquids.

**EMERGENCY VOICE/ALARM COMMUNICATIONS.** See Section 902.1.

**EXCESS FLOW CONTROL.** See Section 2702.1.

**EXCESS FLOW VALVE.** See Section 3702.1.

**EXHAUSTED ENCLOSURE.** See Section 2702.1.

**EXISTING.** Buildings, facilities or conditions which are already in existence, constructed or officially authorized prior to the adoption of this code.

**[B] EXIT.** See Section 1002.1.

**[B] EXIT ACCESS.** See Section 1002.1.

**[B] EXIT DISCHARGE.** See Section 1002.1.

**[B] EXIT DISCHARGE, LEVEL OF.** See Section 1002.1.

**[B] EXIT ENCLOSURE.** See Section 1002.1.

**[B] EXIT, HORIZONTAL.** See Section 1002.1.

**[B] EXIT PASSAGEWAY.** See Section 1002.1.

**EXPANDED PLASTIC.** See Section 2302.1.

**EXPLOSION.** See Section 2702.1.

**EXPLOSIVE.** See Section 3302.1.

**High Explosive.** See Section 3302.1.

**Low Explosive.** See Section 3302.1.

**Mass-detonating Explosives.** See Section 3302.1.

**UN/DOTn Class 1 Explosives.** See Section 3302.1.

**Division 1.1.** See Section 3302.1.

**Division 1.2.** See Section 3302.1.

**Division 1.3.** See Section 3302.1.

**Division 1.4.** See Section 3302.1.

**Division 1.5.** See Section 3302.1.

**Division 1.6.** See Section 3302.1.

**EXPLOSIVE MATERIAL.** See Section 3302.1.

**EXTRA-HIGH-RACK COMBUSTIBLE STORAGE.** See Section 2302.1.

**FABRICATION AREA.** See Section 1802.1.

**FACILITY.** A building or use in a fixed location including exterior storage areas for flammable and combustible substances and hazardous materials, piers, wharves, tank farms and similar uses. This term includes recreational vehicles, mobile home and manufactured housing parks, sales and storage lots.

**FALLOUT AREA.** See Section 3302.1.

**FALSE ALARM.** The willful and knowing initiation or transmission of a signal, message or other notification of an event of fire when no such danger exists.

**FINES.** See Section 1902.1.

**FIRE ALARM.** The giving, signaling or transmission to the chief information to the effect that there is a fire, unauthorized discharge of hazardous materials or emergency condition exists.

**FIRE ALARM BOX, MANUAL.** See Section 902.1.

**FIRE ALARM CONTROL UNIT.** See Section 902.1.

**FIRE ALARM SIGNAL.** See Section 902.1.

**FIRE ALARM SYSTEM.** See Section 902.1.

**FIRE APPARATUS ACCESS GATES.** See Section 502.

**FIRE APPARATUS ACCESS ROAD.** See Section 502.

**FIRE APPARATUS ACCESS ROAD.** See Section 502.1.

**FIRE AREA.** See Section 902.1.

**FIRE CHIEF.** The chief officer of the fire department serving the jurisdiction, or a duly authorized representative.

**FIRE CODE OFFICIAL.** The fire chief or other designated authority charged with the administration and enforcement of the code, or a duly authorized representative.

**FIRE COMMAND CENTER.** See Section 502.1.

**FIRE DETECTOR, AUTOMATIC.** See Section 902.1.

**[B] FIRE DOOR ASSEMBLY.** Any combination of a fire door, frame, hardware, and other accessories that together provide a specific degree of fire protection to the opening.

**[B] FIRE EXIT HARDWARE.** See Section 1002.1.

**FIRE LANE.** See Fire Apparatus Access Road.

**FIRE FLOW.** See Section 502.

**[B] FIRE PARTITION.** A vertical assembly of materials designed to restrict the spread of fire in which openings are protected.

**FIRE POINT.** See Section 3402.1.

**FIRE PROTECTION SYSTEM.** See Section 902.1.

**FIRE SAFETY FUNCTIONS.** See Section 902.1.

## DEFINITIONS

**FIREFIGHTER ACCESS WALKWAY.** See Section 502.

**FIREFIGHTER AIR SYSTEM.** A piping network and associated components installed in building stairwells or other approved locations that is designed to deliver breathing air to firefighters supplied from fire department apparatus that use a connection located outside of a building.

**FIRE WATCH.** A temporary measure intended to ensure continuous and systematic surveillance of a building or portion thereof by one or more qualified individuals for the purposes of identifying and controlling fire hazards, detecting early signs of unwanted fire, raising an alarm of fire and notifying the fire department.

**FIREWORKS.** See Section 3302.1.

**Fireworks, 1.4G.** See Section 3302.1.

**Fireworks, 1.3G.** See Section 3302.1.

**FIREWORKS DISPLAY.** See Section 3302.1.

**FLAMMABLE CRYOGENIC FLUID.** See Section 3202.1.

**FLAMMABLE FINISHES.** See Section 1502.1.

**FLAMMABLE GAS.** See Section 3502.1.

**FLAMMABLE LIQUEFIED GAS.** See Section 3502.1.

**FLAMMABLE LIQUID.** See Section 3402.1.

**Class IA.** See Section 3402.1.

**Class IB.** See Section 3402.1.

**Class IC.** See Section 3402.1.

**FLAMMABLE MATERIAL.** A material capable of being readily ignited from common sources of heat or at a temperature of 600°F (316°C) or less.

**FLAMMABLE SOLID.** See Section 3602.1.

**FLAMMABLE VAPORS OR FUMES.** See Section 2702.1.

**FLASH POINT.** See Section 3402.1.

**FLEET VEHICLE MOTOR FUEL-DISPENSING FACILITY.** See Section 2202.1.

**[B] FLOOR AREA, GROSS.** See Section 1002.1.

**[B] FLOOR AREA, NET.** See Section 1002.1.

**FLUIDIZED BED.** See Section 1502.1.

**FOAM-EXTINGUISHING SYSTEM.** See Section 902.1.

**FUEL LIMIT SWITCH.** See Section 3402.1.

**FUMIGANT.** See Section 1702.1.

**FUMIGATION.** See Section 1702.1.

**GAS CABINET.** See Section 2702.1.

**GAS ROOM.** See Section 2702.1.

**[B] GUARD.** See Section 1002.1.

**HALOGENATED EXTINGUISHING SYSTEM.** See Section 902.1.

**HANDLING.** See Section 2702.1.

**[B] HANDRAIL.** See Section 1002.1.

**HAZARDOUS MATERIAL.** See Section 2702.1.

**HAZARDOUS PRODUCTION MATERIAL (HPM).** See Section 1802.1.

**HEALTH HAZARD.** See Section 2702.1.

**HELIPORT.** See Section 1102.1.

**HELISTOP.** See Section 1102.1.

**HI-BOY.** See Section 302.1.

**HIGH-PILED COMBUSTIBLE STORAGE.** See Section 2302.1.

**HIGH-PILED STORAGE AREA.** See Section 2302.1.

**HIGHLY TOXIC.** See Section 3702.1.

**HIGHLY VOLATILE LIQUID.** A liquefied compressed gas with a boiling point of less than 68°F (20°C).

**HIGHWAY.** See Section 3302.1.

**HOGGED MATERIALS.** See Section 1902.1.

**[M] HOOD.** See Section 602.1.

**Type I.** See Section 602.1.

**HOT WORK.** See Section 2602.1.

**HOT WORK AREA.** See Section 2602.1.

**HOT WORK EQUIPMENT.** See Section 2602.1.

**HOT WORK PERMITS.** See Section 2602.1.

**HOT WORK PROGRAM.** See Section 2602.1.

**HPM FLAMMABLE LIQUID.** See Section 1802.1.

**HPM ROOM.** See Section 1802.1.

**IMMEDIATELY DANGEROUS TO LIFE AND HEALTH (IDLH).** See Section 2702.1.

**IMPAIRMENT COORDINATOR.** See Section 902.1.

**INCOMPATIBLE MATERIALS.** See Section 2702.1.

**INHABITED BUILDING.** See Section 3302.1.

**INTERLOCUTORY RULING.** A court judgement that is not final until the judge decides other matters in the case or until enough time has passed to see if the interim decision is working. See Section 109.

**INTERMEDIATE BULK CONTAINER (IBC).** A rigid or flexible portable package, other than a cylinder or portable tank, having a minimum capacity of 119 gallons (450 L) and a maximum capacity of 793 gallons (3000 L) and is designed for mechanical handling. Standards for IBC's manufactured in the United States are set forth in CFR 49, Part 178, Subparts N and O.

**INITIATING DEVICE.** See Section 902.1.

**INTERIOR FIRE APPARATUS ACCESS ROADS.** See Section 502.

**IRRITANT.** A chemical which is not corrosive, but which causes a reversible inflammatory effect on living tissue by chemical action at the site of contact. A chemical is a skin irritant if, when tested on the intact skin of albino rabbits by the methods of CPSC 16CFR Part 1500.41 for an exposure of four or more hours or by other appropriate techniques, it results in an empirical score of 5 or more. A chemical is classified as an

eye irritant if so determined under the procedure listed in CPSC 16CFR Part 1500.42 or other approved techniques.

**KEY BOX.** See Section 502.1.

**LABELED.** Equipment or material to which has been attached a label, symbol or other identifying mark of an organization that is acceptable to the fire code official and concerned with product evaluation that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

**LIMITED SPRAYING SPACE.** See Section 1502.1.

**LIQUEFIED NATURAL GAS (LNG).** See Section 2202.1.

**LIQUEFIED PETROLEUM GAS (LP-gas).** See Section 3802.1.

**LIQUID.** See Section 2702.1.

**LIQUID STORAGE ROOM.** See Section 3402.1.

**LISTED.** Equipment, materials or services included in a list published by an organization that is acceptable to the chief and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either equipment, materials or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

**LONGITUDINAL FLUE SPACE.** See Section 2302.1.

**LOW-PRESSURE TANK.** See Section 3202.1.

**LOWER EXPLOSIVE LIMIT (LEL).** See Section 2702.1.

**LOWER FLAMMABLE LIMIT (LFL).** See Section 2702.1.

**MAGAZINE.** See Section 3302.1.

**Indoor.** See Section 3302.1.

**Type 1.** See Section 3302.1.

**Type 2.** See Section 3302.1.

**Type 3.** See Section 3302.1.

**Type 4.** See Section 3302.1.

**Type 5.** See Section 3302.1.

**MAGNESIUM.** See Section 3602.1.

**MANUAL FIRE ALARM BOX.** See Section 902.1.

**MANUAL STOCKING METHODS.** See Section 2302.1.

**MARINE MOTOR FUEL-DISPENSING FACILITY.** See Section 2202.1.

**MATERIAL SAFETY DATA SHEET (MSDS).** See Section 2702.1.

**MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA.** See Section 2702.1.

**[B] MEANS OF EGRESS.** See Section 1002.1.

**MECHANICAL STOCKING METHODS.** See Section 2302.1.

**MEMBRANE STRUCTURE.** See Section 2402.1.

**MOBILE FUELING.** See Section 3402.1.

**MORTAR.** See Section 3302.1.

**MULTIPLE-STATION ALARM DEVICE.** See Section 902.1.

**MULTIPLE-STATION SMOKE ALARM.** See Section 902.1.

**NESTING.** See Section 3002.1.

**NET EXPLOSIVE WEIGHT (net weight).** See Section 3302.1.

**NORMAL TEMPERATURE AND PRESSURE (NTP).** See Section 2702.1.

**[B] NOSING.** See Section 1002.1.

**NUISANCE ALARM.** See Section 902.1.

**OCCUPANCY CLASSIFICATION.** For the purposes of this code, certain occupancies are defined as follows:

**[B] Assembly Group A.** Assembly Group A occupancy includes, among others, the use of a building or structure, or a portion thereof, for the gathering together of persons for purposes such as civic, social or religious functions, recreation, food or drink consumption or awaiting transportation. A room or space used for assembly purposes by less than 50 persons and accessory to another occupancy shall be included as a part of that occupancy. Assembly areas with less than 750 square feet (69.7 m<sup>2</sup>) and which are accessory to another occupancy according to Section 302.2.1 of the *International Building Code* are not assembly occupancies. Assembly occupancies which are accessory to Group E in accordance with Section 302.2 of the *International Building Code* are not considered assembly occupancies. Religious educational rooms and religious auditoriums which are accessory to churches in accordance with Section 302.2 of the *International Building Code* and which have occupancy loads of less than 100 shall be classified as A-3. A building or tenant space used for assembly purposes by less than 50 persons shall be considered a Group B occupancy.

Assembly occupancies shall include the following:

**A-1** Assembly uses, usually with fixed seating, intended for the production and viewing of performing arts or motion pictures including but not limited to:

- Motion picture theaters
- Symphony and concert halls
- Television and radio studios admitting an audience
- Theaters

**A-2** Assembly uses intended for food and/or drink consumption including, but not limited to:

- Banquet halls
- Night clubs
- Restaurants
- Taverns and bars

**A-3** Assembly uses intended for worship, recreation or amusement and other assembly uses not classified elsewhere in Group A, including, but not limited to:

- Amusement arcades
- Art galleries
- Bowling alleys

## DEFINITIONS

- Churches
- Community halls
- Courtrooms
- Dance halls (not including food or drink consumption)
- Exhibition halls
- Funeral parlors
- Gymnasiums (without spectator seating)
- Indoor swimming pools (without spectator seating)
- Indoor tennis courts (without spectator seating)
- Lecture halls
- Libraries
- Museums
- Waiting areas in transportation terminals
- Pool and billiard parlors

**A-4** Assembly uses intended for viewing of indoor sporting events and activities with spectator seating including, but not limited to:

- Arenas
- Skating rinks
- Swimming pools
- Tennis courts

**A-5** Assembly uses intended for participation in or viewing outdoor activities including, but not limited to:

- Amusement park structures
- Bleachers
- Grandstands
- Stadiums

**[B] Business Group B.** Business Group B occupancy includes, among others, the use of a building or structure, or a portion thereof, for office, professional or service-type transactions, including storage of records and accounts. Business occupancies shall include, but not be limited to, the following:

- Airport traffic control towers
- Animal hospitals, kennels, pounds
- Banks
- Barber and beauty shops
- Car wash
- Civic administration
- Clinic—outpatient
- Dry cleaning and laundries; pick-up and delivery stations and self-service
- Educational occupancies above the 12th grade
- Electronic data processing
- Laboratories; testing and research
- Motor vehicle showrooms
- Post offices
- Print shops
- Professional services (architects, attorneys, dentists, physicians, engineers, etc.)
- Radio and television stations
- Telephone exchanges

**[B] Educational Group E.** Educational Group E occupancy includes, among others, the use of a building or structure, or a portion thereof, by six or more persons at any one time for educational purposes through the 12th grade. Religious educational rooms and religious auditoriums, which

are accessory to churches in accordance with Section 302.2 and have occupant loads of less than 100, shall be classified as Group A-3 occupancies.

**Day care.** The use of a building or structure, or portion thereof, for educational, supervision or personal care services for more than five children older than 2<sup>1</sup>/<sub>2</sub> years of age shall be classified as an E occupancy.

**[B] Factory Industrial Group F.** Factory Industrial Group F occupancy includes, among others, the use of a building or structure, or a portion thereof, for assembling, disassembling, fabricating, finishing, manufacturing, packaging, repair or processing operations that are not classified as a Group H high-hazard or Group S storage occupancy.

**Factory Industrial F-1 Moderate-Hazard Occupancy.** Factory Industrial uses which are not classified as Factory Industrial Group F-2 shall be classified as F-1 Moderate Hazard and shall include, but not be limited to, the following:

- Aircraft
- Appliances
- Athletic equipment
- Automobiles and other motor vehicles
- Bakeries
- Beverages; over 12 percent in alcohol content
- Bicycles
- Boats
- Brooms or brushes
- Business machines
- Cameras and photo equipment
- Canvas and similar fabric
- Carpet and rugs (includes cleaning)
- Disinfectants
- Dry cleaning and dyeing
- Electric generation plants
- Electronics
- Engines (including rebuilding)
- Food processing
- Furniture
- Hemp products
- Jute products
- Laundries
- Leather products
- Machinery
- Metals
- Millwork (sash and doors)
- Motion picture and television filming (without spectators)
- Musical instruments
- Optical goods
- Paper mills or products
- Photographic film
- Plastic products
- Printing or publishing
- Recreational vehicles
- Refuse incineration
- Shoes
- Soaps and detergents
- Textiles
- Tobacco

Trailers  
 Upholstering  
 Wood; distillation  
 Woodworking (cabinet)

**[B] Factory Industrial F-2 Low-Hazard Occupancy.**

Factory industrial uses involving the fabrication or manufacturing of noncombustible materials which, during finishing, packaging or processing do not involve a significant fire hazard, shall be classified as Group F-2 occupancies and shall include, but not be limited to, the following:

Beverages; up to and including 12 percent alcohol content  
 Brick and masonry  
 Ceramic products  
 Foundries  
 Glass products  
 Gypsum  
 Ice  
 Metal products (fabrication and assembly)

**High-Hazard Group H.** High-hazard Group H occupancy includes, among others, the use of a building or structure, or a portion thereof, that involves the manufacturing, processing, generation or storage of materials that constitute a physical or health hazard in quantities in excess of quantities allowed in control areas constructed and located as required in Section 2703.8.3.

Hazardous uses are classified in Groups H-1, H-2, H-3, H-4 and H-5 and shall be in accordance with this code and the requirements of Section 415 of the *International Building Code*.

**Exception:** The following shall not be classified in Group H, but shall be classified in the occupancy which they most nearly resemble.

1. Buildings and structures that contain not more than the maximum allowable quantities per control area of hazardous materials as shown in Tables 307.7(1) and 307.7(2) of the *International Building Code*, provided that such buildings are maintained in accordance with this code.
2. Buildings utilizing control areas in accordance with Section 414.2 of the *International Building Code* that contain not more than the maximum allowable quantities per control area of hazardous materials as shown in Tables 307.7(1) and 307.7(2) of the *International Building Code*.
3. Buildings and structures occupied for the application of flammable finishes, provided that such buildings or areas conform to the requirements of Section 416 of the *International Building Code* and Chapter 15 of this code.
4. Wholesale and retail sales and storage of flammable and combustible liquids in mercantile occupancies conforming to Chapter 34 of this code.

5. Closed systems housing flammable or combustible liquids or gases utilized for the operation of machinery or equipment.
6. Cleaning establishments that utilize combustible liquid solvents having a flash point of 140°F (60°C) or higher in closed systems employing equipment listed by an approved testing agency, provided that this occupancy is separated from all other areas of the building by 1-hour fire-resistance-rated fire barriers.
7. Cleaning establishments, which utilize a liquid solvent having a flash point at or above 200°F (93°C).
8. Liquor stores and distributors without bulk storage.
9. Refrigeration systems.
10. The storage or utilization of materials for agricultural purposes on the premises.
11. Stationary batteries utilized for facility emergency power, uninterrupted power supply or telecommunication facilities, provided that the batteries are provided with safety venting caps and ventilation is provided in accordance with the *International Building Code*.
12. Corrosives shall not include personal or household products in their original packaging used in retail display or commonly used building materials.
13. Buildings and structures occupied for aerosol storage shall be classified as Group S-1, provided that such buildings conform to the requirements of Chapter 28 of this code.
14. Display and storage of nonflammable solid and nonflammable or noncombustible liquid hazardous materials in quantities not exceeding the maximum allowable quantity per control area in Group M or S occupancies complying with Section 414.2.4 of the *International Building Code*.
15. The storage of black powder, smokeless propellant and small arms primers in Groups M and R-3 and special industrial explosive devices in Groups B, F, M and S, provided such storage conforms to the quantity limits and requirements of this code.

**High-hazard Group H-1.** Buildings and structures containing materials that pose a detonation hazard, shall be classified as Group H-1. Such materials shall include, but not be limited to, the following:

Explosives:  
 Division 1.1  
 Division 1.2  
 Division 1.3

**Exception:** Materials that are used and maintained in a form where either confinement or configuration will not elevate the hazard from a

## DEFINITIONS

mass fire to mass explosion hazard shall be allowed in Group H-2 occupancies.

### Division 1.4

**Exception:** Articles, including articles packaged for shipment, that are not regulated as an explosive under Bureau of Alcohol, Tobacco, Firearms & Explosives (BATF & E) regulations, or unpackaged articles used in process operations that do not propagate a detonation or deflagration between articles shall be allowed in Group H-3 occupancies.

### Division 1.5

### Division 1.6

Organic peroxides, unclassified detonable

Oxidizers, Class 4

Unstable (reactive) materials, Class 3 detonable, and Class 4

Detonable pyrophoric materials

**High-hazard Group H-2.** Buildings and structures containing materials that pose a deflagration hazard or a hazard from accelerated burning, shall be classified as Group H-2. Such materials shall include, but not be limited to, the following:

Class I, or II or IIIA flammable or combustible liquids which are used or stored in normally open containers or systems, or in closed containers or systems pressurized at more than 15 pounds per square inch (103.4 kPa) gauge

Combustible dusts

Cryogenic fluids, flammable

Flammable gases

Organic peroxides, Class I

Oxidizers, Class 3, that are used or stored in normally open containers or systems, or in closed containers or systems pressurized at more than 15 pounds per square inch (103.4 kPa) gauge

Pyrophoric liquids, solids and gases, nondetonable

Unstable (reactive) materials, Class 3, nondetonable

Water-reactive materials, Class 3

**High-hazard Group H-3.** Buildings and structures containing materials that readily support combustion or that pose a physical hazard shall be classified as Group H-3. Such materials shall include, but not be limited to, the following:

Class I, II or IIIA flammable or combustible liquids which are used or stored in normally closed containers or systems pressurized at less than 15 pounds per square inch (103.4 kPa) gauge

Combustible fibers

Consumer fireworks, 1.4G (Class C, Common)

Cryogenic fluids, oxidizing

Flammable solids

Organic peroxides, Class II and Class III

Oxidizers, Class 2

Oxidizers, Class 3, that are used or stored in normally closed containers or systems pressurized at less than 15 pounds per square inch (103.4 kPa) gauge

Oxidizing gases

Unstable (reactive) materials, Class 2

Water-reactive materials, Class 2

**High-hazard Group H-4.** Buildings and structures which contain materials that are health hazards shall be classified as Group H-4. Such materials shall include, but not be limited to, the following:

Corrosives

Highly toxic materials

Toxic materials

**High-hazard Group H-5.** Semiconductor fabrication facilities and comparable research and development areas in which hazardous production materials (HPM) are used and the aggregate quantity of materials is in excess of those listed in Tables 307.7(1) and 307.7(2) of the *International Building Code* shall be classified as Group H-5. Such facilities and areas shall be designed and constructed in accordance with Section 415.9 of the *International Building Code*.

**[B] Institutional Group I.** Institutional Group I occupancy includes, among others, the use of a building or structure, or a portion thereof, in which people, cared for or living in a supervised environment and having physical limitations because of health or age, are harbored for medical treatment or other care or treatment, or in which people are detained for penal or correctional purposes or in which the liberty of the occupants is restricted. Institutional occupancies shall be classified as Group I-1, I-2, I-3 or I-4.

**Group I-1.** This occupancy shall include buildings, structures or parts thereof housing more than 16 persons, on a 24-hour basis, who because of age, mental disability or other reasons, live in a supervised residential environment that provides personal care services. The occupants are capable of responding to an emergency situation without physical assistance from staff. This group shall include, but not be limited to, the following:

Alcohol and drug centers

Assisted living facilities

Congregate care facilities

Convalescent facilities

Group homes

Half-way houses

Residential board and care facilities

Social rehabilitation facilities

A facility such as the above with five or fewer persons shall be classified as Group R-3 or shall comply with the *International Residential Code*. A facility such as above, housing at least six and not more than 16 persons, shall be classified as Group R-4.

**Group I-2.** This occupancy shall include buildings and structures used for medical, surgical, psychiatric, nursing or custodial care on a 24-hour basis of more than five persons who are not capable of self-preservation. This group shall include, but not be limited to, the following:

Hospitals

Nursing homes (both intermediate care facilities and skilled nursing facilities)

Mental hospitals  
Detoxification facilities.

A facility such as the above with five or fewer persons shall be classified as Group R-3 or shall comply with the *International Residential Code*.

A child care facility which provides care on a 24-hour basis to more than five children 2<sup>1</sup>/<sub>2</sub> years of age or less shall be classified as Group I-2.

**Group I-3.** Except for privately owned and operated facilities, this occupancy is under the jurisdiction of the State of Arizona and shall include buildings and structures which are inhabited by more than five persons who are under restraint or security. An I-3 facility is occupied by persons who are generally incapable of self-preservation due to security measures not under the occupants' control. This group shall include, but not be limited to, the following:

- Correctional centers
- Detention centers
- Jails
- Prerelease centers
- Prisons
- Reformatories

Buildings of Group I-3 shall be classified as one of the occupancy conditions indicated in Sections 308.4.1 through 308.4.5 (see Section 408.1) of the *International Building Code*.

**Condition 1.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas and other spaces where access or occupancy is permitted, to the exterior via means of egress without restraint. A Condition 1 facility is permitted to be constructed as Group R.

**Condition 2.** This occupancy condition shall include buildings in which free movement is allowed from sleeping areas and any other occupied smoke compartment to one or more other smoke compartments. Egress to the exterior is impeded by locked exits.

**Condition 3.** This occupancy condition shall include buildings in which free movement is allowed within individual smoke compartments, such as within a residential unit comprised of individual sleeping units and group activity spaces, where egress is impeded by remote-controlled release of means of egress from such smoke compartment to another smoke compartment.

**Condition 4.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Remote-controlled release is provided to permit movement from sleeping units, activity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**Condition 5.** This occupancy condition shall include buildings in which free movement is restricted from an occupied space. Staff-controlled manual release is provided to permit movement from sleeping units, ac-

tivity spaces and other occupied areas within the smoke compartment to other smoke compartments.

**Group I-4, day care facilities.** This group shall include buildings and structures occupied by persons of any age who receive custodial care for less than 24 hours by individuals other than parents or guardians, relatives by blood marriage, or adoption, and in a place other than the home of the person cared for. A facility such as the above with five or fewer persons shall be classified as Group R-3 or shall comply with the *International Residential Code*. Places of worship during religious functions are not included.

**Adult care facility.** A facility that provides accommodations for less than 24 hours for more than five unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

**Exception:** Where the occupants are capable of responding to an emergency situation without physical assistance from the staff the facility shall be classified as Group A-3.

**Child care facility.** A facility that provides supervision and personal care on less than a 24-hour basis for more than five children 2<sup>1</sup>/<sub>2</sub> years of age or less shall be classified as Group I-4.

**Exception:** A child day care facility which provides care for more than five but no more than 100 children 2<sup>1</sup>/<sub>2</sub> years or less of age, when the rooms where such children are cared for are located on the level of exit discharge and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group E.

**[B] Mercantile Group M.** Mercantile Group M occupancy includes, among others, buildings and structures or a portion thereof, for the display and sale of merchandise, and involves stocks of goods, wares or merchandise incidental to such purposes and accessible to the public. Mercantile occupancies shall include, but not be limited to, the following.

- Department stores
- Drug stores
- Markets
- Motor fuel-dispensing facilities
- Retail or wholesale stores
- Sales rooms

**[B] Residential Group R.** Residential Group R includes, among others, the use of a building or structure, or a portion thereof, for sleeping purposes when not classed as Institutional Group I. Residential occupancies shall include the following:

**R-1** Residential occupancies where the occupants are primarily transient in nature including:

- Boarding houses (transient)
- Hotels (transient)
- Motels (transient)

**R-2** Residential occupancies containing sleeping units or more than two dwelling units where the occupants are primarily permanent in nature, including:

- Apartment houses
- Boarding houses (not transient)

## DEFINITIONS

Convents  
Dormitories  
Fraternities and sororities  
Hotels (nontransient)  
Monasteries  
Motels (nontransient)  
Vacation timeshare properties

**R-3** Residential occupancies where the occupants are primarily permanent in nature and not classified as R-1, R-2, or I and where buildings do not contain more than two dwelling units as applicable in Section 101.2 of the *International Building Code*, or adult and child care facilities that provide accommodations for five or fewer persons of any age for less than 24-hours. Adult and child care facilities that are within a single-family home are permitted to comply with the *International Residential Code*.

**R-4** Residential occupancies shall include buildings arranged for occupancy for ambulatory, nonrestrained persons who may have a mental or physical impairment as Residential Care/Assisted Living Facilities including more than five but not more than 16 occupants, excluding staff.

Group R-4 occupancies shall meet the requirements for construction as defined for Group R-3 except for the height and area limitations provided in Section 503 of the *International Building Code* or shall comply with the *International Residential Code*.

**[B] Storage Group S.** Storage Group S occupancy includes, among others, the use of a building or structure, or a portion thereof, for storage that is not classified as a hazardous occupancy.

**Moderate-hazard storage, Group S-1.** Buildings occupied for storage uses which are not classified as Group S-2 including, but not limited to, storage of the following:

Aerosols, Level 2 and 3  
Aircraft repair hangar  
Bags, cloth, burlap and paper  
Bamboo and rattan  
Baskets  
Belting, canvas and leather  
Books and paper in rolls or packs  
Boots and shoes  
Buttons, including cloth covered, pearl or bone  
Cardboard and cardboard boxes  
Clothing, woolen wearing apparel  
Cordage  
Dry boat storage (indoor)  
Furniture  
Furs  
Glue, mucilage, paste and size  
Grain  
Horn and combs, other than celluloid  
Leather  
Linoleum  
Lumber  
Motor vehicle repair garages (complying with the

*International Building Code* and containing less than the maximum allowable quantities of hazardous materials)  
Photo engravings  
Resilient flooring  
Silks  
Soaps  
Sugar  
Tires, bulk storage of  
Tobacco, cigars, cigarettes and snuff  
Upholstering and mattress  
Wax candles

**Low-hazard storage, Group S-2.** Includes, among others, buildings used for the storage of noncombustible materials such as products on wood pallets or in paper cartons with or without single thickness divisions; or in paper wrappings. Such products may have a negligible amount of plastic trim such as knobs, handles, or film wrapping. Storage uses shall include, but not be limited to, storage of the following:

Aircraft hangar  
Asbestos  
Beverages up to and including 12-percent alcohol in metal, glass or ceramic containers  
Cement in bags  
Chalk and crayons  
Dairy products in nonwaxed coated paper containers  
Dry cell batteries  
Electrical coils  
Electrical motors  
Empty cans  
Food products  
Foods in noncombustible containers  
Fresh fruits and vegetables in nonplastic trays or containers  
Frozen foods  
Glass  
Glass bottles, empty or filled with noncombustible liquids  
Gypsum board  
Inert pigments  
Ivory  
Metal desks with plastic tops and trim  
Metal parts  
Metals  
Mirrors  
Oil-filled and other types of distribution transformers  
Parking garages (open or enclosed)  
Porcelain and pottery  
Stoves  
Talc and soapstones  
Washers and dryers

**[B] Miscellaneous Group U.** Buildings and structures of an accessory character and miscellaneous structures not classified in any specific occupancy shall be constructed, equipped and maintained to conform to the requirements of this code commensurate with the fire and life hazard incidental to their occupancy. Group U shall include, but not be limited to, the following:

Agricultural buildings  
 Aircraft hangar, accessory to a one- or two-family residence (see Section 412.3 of the *International Building Code*)  
 Barns  
 Carports  
 Fences more than 6 feet (1829 mm) high  
 Grain silos, accessory to a residential occupancy  
 Greenhouses  
 Livestock shelters  
 Private garages  
 Retaining walls  
 Sheds  
 Stables  
 Tanks  
 Towers

**[B] OCCUPANT LOAD.** See Section 1002.1.

**OPEN BURNING.** See Section 302.1.

**OPEN SYSTEM.** The use of a solid or liquid hazardous material involving a vessel or system that is continuously open to the atmosphere during normal operations and where vapors are liberated, or the product is exposed to the atmosphere during normal operations. Examples of open systems for solids and liquids include dispensing from or into open beakers or containers, dip tank and plating tank operations.

**OPERATING BUILDING.** See Section 3302.1.

**OPERATING LINE.** See Section 3302.1.

**OPERATING PRESSURE.** The pressure at which a system operates.

**ORGANIC COATING.** See Section 2002.1.

**ORGANIC PEROXIDE.** See Section 3902.1.

**Class I.** See Section 3902.1.

**Class II.** See Section 3902.1.

**Class III.** See Section 3902.1.

**Class IV.** See Section 3902.1.

**Class V.** See Section 3902.1.

**Unclassified detonable.** See Section 3902.1.

**OUTDOOR ASSEMBLY EVENTS.** Outdoor assembly events are conducted outdoors, have a projected attendance of 500 or more persons or confine 50 or more attendees by the permanent or temporary installation of barricades or fencing.

**Exception:** Group R-3 Occupancies.

**OUTDOOR CONTROL AREA.** See Section 2702.1.

**OUTDOOR FIREWORKS.** See Section 3308.

**OVERCROWDING.** A condition that exists when either there are more people in a building, structure or portion thereof than have been authorized or posted by the fire code official, or when the fire code official determines that a threat exists to the safety of the occupants due to persons sitting and/or standing in locations that may obstruct or impede the use of aisles, passages, corridors, stairways, exits or other components of the means of egress.

**OWNER.** A corporation, firm, partnership, association, organization and any other group acting as a unit, or a person who

has legal title to any structure or premises with or without accompanying actual possession thereof, and shall include the duly authorized agent or attorney, a purchaser, devisee, fiduciary and any person having a vested or contingent interest in the premises in question.

**OXIDIZER.** See Section 4002.1.

**Class 4.** See Section 4002.1.

**Class 3.** See Section 4002.1.

**Class 2.** See Section 4002.1.

**Class 1.** See Section 4002.1.

**OXIDIZING GAS.** See Section 4002.1.

**OZONE-GAS GENERATOR.** See Section 3702.1.

**[B] PANIC HARDWARE.** See Section 1002.1.

**PASS-THROUGH.** See Section 1802.1.

**PEDESTRIAN GATES.** See Section 502.

**PERMISSIBLE EXPOSURE LIMIT (PEL).** See Section 2702.1.

**PESTICIDE.** See Section 2702.1.

**PHYSICAL HAZARD.** See Section 2702.1.

**PHYSIOLOGICAL WARNING THRESHOLD.** See Section 3702.1.

**PLOSOPHORIC MATERIAL.** See Section 3302.1.

**PLYWOOD and VENEER MILLS.** See Section 1902.1.

**POWERED INDUSTRIAL TRUCK.** See Section 302.1.

**PREEMPTION DEVICE.** See Section 502.

**PRESSURE VESSEL.** See Section 2702.1.

**PRIMARY CONTAINMENT.** The first level of containment, consisting of the inside portion of that container which comes into immediate contact on its inner surface with the material being contained.

**PROCESS TRANSFER.** See Section 3402.1.

**PROPELLANT.** See Section 2802.1.

**PROXIMATE AUDIENCE.** See Section 3302.1.

**PUBLIC TRAFFIC ROUTE (PTR).** See Section 3302.1.

**[B] PUBLIC WAY.** See Section 1002.1.

**PYROPHORIC.** See Section 4102.1.

**PYROTECHNIC COMPOSITION.** See Section 3302.1.

**PYROTECHNIC MATERIAL.** See Section 3302.1.

**PYROTECHNIC OPERATOR.**

**PYROTECHNICS QUANTITY-DISTANCE (Q-D).** See Section 3302.1.

**Minimum Separation Distance (D<sub>0</sub>).** See Section 3302.1  
**Intraline Distance (ILD) or Intraplant Distance (IPD).** See Section 3302.1.

**Inhabited Building Distance (IBD).** See Section 3302.1.  
**Intermagazine Distance (IMD).** See Section 3302.1.

**RAILWAY.** See Section 3302.1.

**[B] RAMP.** See Section 1002.1.

## DEFINITIONS

**RAPID INTERVENTION CREW UNIVERSAL AIR CONNECTION (RIC UAC).** A connection that allows emergency replenishment of breathing air to the self-contained breathing apparatus of fire or emergency services personnel.

**RAW PRODUCT.** See Section 1902.1.

**READY BOX.** See Section 3302.1.

**RECORD DRAWINGS.** See Section 902.1.

**RECREATIONAL FIRE.** See Section 302.1.

**REDUCED FLOW VALVE.** See Section 3702.1.

**REFINERY.** See Section 3402.1.

**REFRIGERANT.** See Section 602.1.

**REFRIGERATION SYSTEM.** See Section 602.1.

**[B] REGISTERED DESIGN PROFESSIONAL.** An architect or engineer, registered or licensed to practice professional architecture or engineering, as defined by the statutory requirements of the professional registration laws of the state in which the project is to be constructed.

**RELEASE.** The accidental or intentional spilling, leaking, pumping, pouring, emitting, emptying or dumping of hazardous materials into a sewer, storm drain, ditch, drainage canal, lake, river or tidal waterway, or upon the ground, sidewalk, street, highway or into the atmosphere.

**REMOTE EMERGENCY SHUTOFF DEVICE.** See Section 3402.1.

**REMOTE SOLVENT RESERVOIR.** See Section 3402.1.

**REMOTELY LOCATED, MANUALLY ACTIVATED SHUTDOWN CONTROL.** A control system that is designed to initiate shutdown of the flow of gases or liquids that is manually activated from a point located some distance from the delivery system.

**REPAIR GARAGE.** See Section 2202.1.

**RESIN APPLICATION AREA.** See Section 1502.1.

**RESPONSIBLE PERSON.** See Section 2602.1.

**RETAIL DISPLAY AREA.** See Section 2802.1.

**ROLL COATING.** See Section 1502.1.

**RUBBISH (TRASH).** Combustible and noncombustible waste materials, including residue from the burning of coal, wood, coke or other combustible material, paper, rags, cartons, tin cans, metals, mineral matter, glass crockery, dust and discarded refrigerators, and heating, cooking or incinerator-type appliances.

**SAFETY CAN.** See Section 2702.1.

**[B] SCISSOR STAIR.** See Section 1002.1.

**SECONDARY CONTAINMENT.** See Section 2702.1.

**SEGREGATED.** See Section 2702.1.

**SELF-SERVICE MOTOR FUEL-DISPENSING FACILITY.** See Section 2202.1.

**SEMICONDUCTOR FABRICATION FACILITY.** See Section 1802.1.

**SERVICE CORRIDOR.** See Section 1802.1.

**SHELF STORAGE.** See Section 2302.1.

**SINGLE-STATION SMOKE ALARM.** See Section 902.1.

**[B] SLEEPING UNIT.** See Section 902.1.

**SMALL ARMS AMMUNITION.** See Section 3302.1.

**SMALL ARMS PRIMERS.** See Section 3302.1.

**SMOKE ALARM.** See Section 902.1.

**SMOKE DETECTOR.** See Section 902.1.

**[B] SMOKE-PROTECTED ASSEMBLY SEATING.** See Section 1002.1.

**SMOKELESS PROPELLANTS.** See Section 3302.1.

**SOLID.** See Section 2702.1.

**SOLID SHELVING.** See Section 2302.1.

**SOLVENT DISTILLATION UNIT.** See Section 3402.1.

**SOLVENT OR LIQUID CLASSIFICATIONS.** See Section 1202.1.

**Class I solvents.** See Section 1202.1.

**Class II solvents.** See Section 1202.1.

**Class IIIA solvents.** See Section 1202.1.

**Class IIIB solvents.** See Section 1202.1.

**Class IV solvents.** See Section 1202.1.

**SPECIAL AMUSEMENT BUILDING.** A building that is temporary, permanent or mobile used for entertainment purposes that contains a device or system that conveys passengers or provides a walkway along, around or over a course in any direction as a form of amusement arranged so that the egress path is not readily apparent due to visual or audio distractions or an intentionally confounded egress path, or is not readily available because of the mode of conveyance through the building or structure.

**SPECIAL INDUSTRIAL EXPLOSIVE DEVICE.** See Section 3302.1.

**SPRAY AREA.** See Section 1502.1.

**SPRAY BOOTH.** See Section 1502.1.

**SPRAY ROOM.** See Section 1502.1.

**SPREAD NUMBERS.** See Section 502.

**SPREAD PLATE.** See Section 505. A permanent sign that identifies individual dwelling units at a common entrance of a building.

**[B] STAIR.** See Section 1002.1.

**[B] STAIRWAY.** See Section 1002.1.

**[B] STAIRWAY, EXTERIOR.** See Section 1002.1.

**[B] STAIRWAY, INTERIOR.** See Section 1002.1.

**[B] STAIRWAY, SPIRAL.** See Section 1002.1.

**STANDBY POWER SYSTEM.** An electrical system where the current supply is designed such that in the event of interruption of the normal power supply, a second source of adequate capacity and rating is available within 60 seconds of power failure.

**STANDPIPE SYSTEM, CLASSES OF.** See Section 902.1.

**Class I system.** See Section 902.1.  
**Class II system.** See Section 902.1.  
**Class III system.** See Section 902.1.

**STANDPIPE, TYPES OF.** See Section 902.1.

**Automatic dry.** See Section 902.1.  
**Automatic wet.** See Section 902.1.  
**Manual dry.** See Section 902.1.  
**Manual wet.** See Section 902.1.  
**Semiautomatic dry.** See Section 902.1.

**STATIC PILES.** See Section 1902.1.

**STEEL.** Hot- or cold-rolled as defined by the *International Building Code*.

**STORAGE, HAZARDOUS MATERIALS.** See Section 2702.1.

**SUPERVISING STATION.** See Section 902.1.

**SUPERVISORY SERVICE.** See Section 902.1.

**SUPERVISORY SIGNAL.** See Section 902.1.

**SUPERVISORY SIGNAL-INITIATING DEVICE.** See Section 902.1.

**SYSTEM.** See Section 2702.1.

**TANK.** A vessel containing more than 60 gallons (227 L).

**TANK, ATMOSPHERIC.** See Section 2702.1.

**TANK, PORTABLE.** See Section 2702.1.

**TANK, PRIMARY.** See Section 3402.1.

**TANK, PROTECTED ABOVE GROUND.** See Section 3402.1.

**TANK, STATIONARY.** See Section 2702.1.

**TANK VEHICLE.** See Section 2702.1.

|| **TEMPORARY.** Temporary is 180 days.

**TENT.** See Section 2402.1.

**THEFT RESISTANT.** See Section 3302.1.

**THERMAL INSECTICIDAL FOGGING.** See Section 1702.1.

**TIMBER and LUMBER PRODUCTION FACILITIES.** See Section 1902.1.

**TIRES, BULK STORAGE OF.** See Section 902.1.

**TOOL.** See Section 1802.1.

**TORCH-APPLIED ROOF SYSTEM.** See Section 2602.1.

**TOXIC.** See Section 3702.1.

**TRANSVERSE FLUE SPACE.** See Section 2302.1.

**TRASH.** See "Rubbish."

**TROUBLE SIGNAL.** See Section 902.1.

**UNAUTHORIZED DISCHARGE.** See Section 2702.1.

**UNSTABLE (REACTIVE) MATERIAL.** See Section 4302.1.

**Class 4.** See Section 4302.1.  
**Class 3.** See Section 4302.1.  
**Class 2.** See Section 4302.1.  
**Class 1.** See Section 4302.1.

**UNWANTED FIRE.** A fire not used for cooking, heating or recreational purposes or one not incidental to the normal operations of the property.

**USE (MATERIAL).** See Section 2702.1.

**VALVE-REGULATED LEAD-ACID (VRLA) BATTERY.** See Section 602.1.

**VAPOR AREA.** See Section 1502.1.

**VAPOR PRESSURE.** See Section 2702.1.

**VENTED (FLOODED) LEAD-ACID BATTERY.** See Section 602.1.

**VISIBLE ALARM NOTIFICATION APPLIANCE.** See Section 902.1.

**WATER-REACTIVE MATERIAL.** See Section 4402.1.

**Class 3.** See Section 4402.1.

**Class 2.** See Section 4402.1.

**Class 1.** See Section 4402.1.

**WET-CHEMICAL EXTINGUISHING AGENT.** See Section 902.1.

[B] **WINDER.** See Section 1002.1.

**WIRELESS PROTECTION SYSTEM.** See Section 902.1.

**WORKSTATION.** See Section 1802.1.

**ZONE.** See Section 902.1.

