

## CHAPTER 25

# TIRE REBUILDING AND TIRE STORAGE

### SECTION 2501 GENERAL

**2501.1 Scope.** Tire rebuilding plants, tire storage and tire by-product facilities shall comply with this chapter, other applicable requirements of this code and NFPA 13 and NFPA 230. Tire storage in buildings shall also comply with Chapter 23.

**2501.2 Permit required.** Permits shall be required as set forth in Section 105.6.

**2501.3 Site plans.** At the time of permit application for storing tires outdoors, a site plan shall be submitted to the fire code official identifying the location and dimensions of tire storage areas, tire pile dimensions and height, distance from buildings and property lines, width and location of aisles, and fire apparatus access roads. See Section 105.4.

### SECTION 2502 DEFINITIONS

**2502.1 Terms defined in Chapter 2.** Words and terms used in this chapter and defined in Chapter 2 shall have the meanings ascribed to them as defined therein.

### SECTION 2503 TIRE REBUILDING

**2503.1 Construction.** Tire rebuilding plants shall comply with the requirements of the *International Building Code*, as to construction, separation from other buildings or other portions of the same building, and protection.

**2503.2 Location.** Buffing operations shall be located in a room separated from the remainder of the building housing the tire rebuilding or tire recapping operations by a 1-hour fire barrier.

**Exception:** Buffing operations are not required to be separated where all of the following conditions are met:

1. Buffing operations are equipped with an approved continuous automatic water-spray system directed at the point of cutting action;
2. Buffing machines are connected to particle-collecting systems providing a minimum air movement of 1,500 cubic feet per minute (cfm) (0.71 m<sup>3</sup>/s) in volume and 4,500 feet per minute (fpm) (23 m/s) in-line velocity; and
3. The collecting system shall discharge the rubber particles to an approved outdoor noncombustible or fire-resistant container, which is emptied at frequent intervals to prevent overflow.

**2503.3 Cleaning.** The buffing area shall be cleaned at frequent intervals to prevent the accumulation of rubber particles.

**2503.4 Spray rooms and booths.** Each spray room or spray booth where flammable or combustible solvents are applied, shall comply with Chapter 15.

### SECTION 2504 PRECAUTIONS AGAINST FIRE

**2504.1 Open burning.** Open burning is prohibited in tire storage yards.

**2504.2 Sources of heat.** Cutting, welding or heating devices shall not be operated in tire storage yards.

**2504.3 Smoking prohibited.** Smoking is prohibited in tire storage yards, except in designated areas.

**2504.4 Power lines.** Tire storage piles shall not be located beneath electrical power lines having a voltage in excess of 750 volts or that supply power to fire emergency systems.

**2504.5 Fire safety plan.** The owner or individual in charge of the tire storage yard shall be required to prepare and submit to the fire code official a fire safety plan for review and approval. The fire safety plan shall include provisions for fire department vehicle access. At least one copy of the fire safety plan shall be prominently posted and maintained at the storage yard.

**2504.6 Telephone number.** The telephone number of the fire department and location of the nearest telephone shall be posted conspicuously in attended locations.

### SECTION 2505 OUTDOOR STORAGE

**2505.1 Placement.** Tires shall be placed on solid, level ground.

**2505.2 Individual piles.** Tire storage shall be restricted to individual piles that are 20 feet (6096 mm) wide by 150 feet (47 720 mm) long.

**2505.3 Height.** Outside storage shall not exceed 10 feet in height.

**2505.4 Separation of piles.** Individual tire storage piles shall be separated from other piles of salvage by a clear space of at least 40 feet (12 192 mm).

**2505.5 Distance between piles of other stored products.** Tire storage piles shall be separated by a clear space of at least 40 feet (12 192 mm) from piles of other stored product.

**2505.6 Distance from lot lines and buildings.** Tire storage piles shall be located at least 50 feet (15 240 mm) from lot lines and buildings.

**2505.7 Fire breaks.** Storage yards shall be maintained free from combustible ground vegetation for a distance of 40 feet (12 192 mm) from the stored material to grass and weeds; and for a distance of 100 feet (30 480 mm) from the stored product to brush and forested areas.

## TIRE REBUILDING AND TIRE STORAGE

11 **2505.8 Volume more than 150,000 cubic feet.** Where the bulk volume of stored product is more than 150,000 cubic feet (4248 m<sup>3</sup>), storage arrangement shall be in accordance with the following:

1. Individual storage piles shall comply with size and separation requirements in Sections 2505.1 through 2505.7.
2. Adjacent storage piles shall be considered a group, and the aggregate volume of storage piles in a group shall not exceed 150,000 cubic feet (4248 m<sup>3</sup>).

Separation between groups shall be at least 75 feet (22 860 m) wide.

11 **2505.9 Location of storage.** Outdoor waste tire storage shall not be located under bridges, elevated trestles, elevated roadways or elevated railroads.

**2505.10 Dead end aisles.** No dead-end aisles shall be allowed within the facility.

**2505.11 Stacking.** The method of stacking shall be solid piles in an orderly manner.

**2505.12 Barriers.** When the number of tires stored exceeds 25,000 cubic feet, the storage area shall be surrounded by suitable barriers capable of containing liquid products of combustion resulting from a fire.

**2505.13 Drainage.** Means shall be provided that will prevent the drainage of liquid products of combustion from posing a threat to health or safety or the environment.

## SECTION 2506 FIRE DEPARTMENT ACCESS

**2506.1 Required access.** New and existing tire storage yards shall be provided with fire apparatus access roads in accordance with Section 503 and this section.

**2506.2 Location.** Fire apparatus access roads shall be located within all pile clearances identified in Sections 2505.4 and within all fire breaks required in Section 2505.5. Access roadways shall be within 150 feet (45 720 mm) of any point in the storage yard where storage piles are located, at least 20 feet (6096 mm) from any storage pile.

## SECTION 2507 FENCING

**2507.1 Where required.** A firmly anchored fence or other approved method of security that controls unauthorized access to the storage yard shall surround the storage yard.

**2507.2 Construction.** The fence shall be constructed of approved materials and shall be at least 6 feet (1829 mm) high and provided with gates at least 20 feet (6096 mm) wide.

**2507.3 Locking.** All gates to the storage yard shall be locked when the storage yard is not staffed.

**2507.4 Unobstructed.** Gateways shall be kept clear of obstructions and be fully openable at all times.

## SECTION 2508 FIRE PROTECTION

**2508.1 Water supply.** A public or private fire protection water supply shall be provided in accordance with Section 508. The water supply shall be arranged such that any part of the storage yard can be reached by using not more than 500 feet (152 m) of hose.

**2508.2 Fire extinguishers.** Buildings or structures shall be provided with portable fire extinguishers in accordance with Section 906. Fuel-fired vehicles operating in the storage yard shall be equipped with a minimum 2-A:20-B:C rated portable extinguisher.

## SECTION 2509 RESERVE