

EDITORIAL CHANGES – SECOND PRINTING

Page 22, 304.5: line 2 now reads . . . motor fuel-dispensing facilities, repair garages or other areas

Page 28, 403.3.2: Equation 4-1 now reads . . .
$$Y = \frac{X}{(1 + X - Z)}$$

Page 39, 506.3.1.2: line 4 now reads . . . with Sections 603.1, 603.3, 603.4, 603.9, 603.10 and 603.12.

Page 59, 607.5.4: line 4 now reads . . . barrier wall or a corridor enclosure required to have smoke

EDITORIAL CHANGES –THIRD PRINTING

Page 12, Added definition: ENERGY RECOVERY VENTILATION SYSTEM. Systems that employ air-to-air heat exchangers to recover energy from or reject energy to exhaust air for the purpose of pre-heating, pre-cooling, humidifying or dehumidifying outdoor ventilation air prior to supplying such air to a space, either directly or as part of an HVAC system.

Page 29, TABLE 403.3 — continued: row 2, column 3, line 8 now reads . . . intermittent

Page 31, 501.2: Add arrow above section

Page 32, 502.7.3.2, Exception 1.2: now reads . . . of the lower flammable limit

Page 44, 509.1, now reads . . . Commercial cooking appliances

Page 60, 607.6.2, Added sentence . . . Ceiling radiation dampers shall not be required where exhaust duct penetrations are protected in accordance with Section 712.4.2 of the *International Building Code* and the exhaust ducts are located within the cavity of a wall and do not pass through another dwelling unit or tenant space.

EDITORIAL CHANGES –FOURTH PRINTING

Page 28, 402.3: New exception following this section reads: **Exception:** Exterior openings required for ventilation shall be permitted to open into a thermally isolated sunroom addition or patio cover, provided that the openable area between the sunroom addition or patio cover and the interior room shall have an area of not less than 8 percent of the floor area of the interior room or space, but not less than 20 square feet (1.86 m²). The minimum openable area to the outdoors shall be based on the total floor area being ventilated.

Page 29, TABLE 403.3: row 2, column 1, line 4 now reads . . . with plumbing fixtures^{b,g}

Page 30, TABLE 403.3—continued: row 5, column 1, line 2 now reads . . . Automotive motor-fuel-dispensing stations

Page 48, [B]513.5.1: line 3 now reads . . . allowable leakage area ratio, plus the area of other openings such as gaps and operable windows . . .

Page 55, 603.14: last line now reads . . . with Section 603.8.

Page 96, 1303.3.4: line 2 now reads . . . by an approved procedure. The joint shall be welded with an . . .

