

CHAPTER 7

GASEOUS HYDROGEN SYSTEMS

SECTION 701 (IFGC) GENERAL

701.1 Scope. The installation of gaseous hydrogen systems shall comply with this chapter and Chapters 30 and 35 of the *International Fire Code*. Compressed gases shall also comply with Chapter 27 of the *International Fire Code* for general requirements. Containers provided with pyrophoric material shall also comply with Chapter 41 of the *International Fire Code*. Containers having residual gaseous hydrogen shall be considered as full for the purposes of the controls required.

701.2 Permits. Permits shall be required as set forth in Section 406 115 and as required by the *International Fire Code*.

SECTION 702 (IFGC) GENERAL DEFINITIONS

702.1 Definitions. The following words and terms shall, for the purposes of this chapter and as used elsewhere in this code, have the meanings shown herein.

HYDROGEN CUTOFF ROOM. A room or space which is intended exclusively to house a gaseous hydrogen system.

HYDROGEN-GENERATING APPLIANCE. A self-contained package or factory-matched packages of integrated systems for generating gaseous hydrogen. Hydrogen-generating appliances utilize electrolysis, reformation, chemical or other processes to generate hydrogen.

GASEOUS HYDROGEN SYSTEM. An assembly of piping, devices and apparatus designed to generate, store, contain, distribute or transport a nontoxic, gaseous hydrogen containing mixture having at least 95-percent hydrogen gas by volume and not more than 1-percent oxygen by volume. Gaseous hydrogen systems consist of items such as compressed gas containers, reactors and appurtenances, including pressure regulators, pressure relief devices, manifolds, pumps, compressors and interconnecting piping and tubing and controls.

SECTION 703 (IFGC) GENERAL REQUIREMENTS

703.1 Hydrogen-generating and refueling operations. Ventilation shall be required in accordance with Section 703.1.1, 703.1.2 or 703.1.3 in public garages, private garages, repair garages, automotive service stations and parking garages which contain hydrogen-generating appliances or refueling systems. Such spaces shall be used for the storage of not more than three hydrogen-fueled passenger motor vehicles and have a floor area not exceeding 850 square feet (79 m²). The maximum rated output capacity of hydrogen-generating appliances shall not exceed 4 standard cubic feet per minute (ft³/min) of hydrogen for each 250 square feet (23.2 m²) of floor area in such spaces. Such equipment and appliances shall not be installed in Group H occupancies except where the occupancy is specifically designed for hydrogen use, or in control areas where open use, handling or dispensing of combustible, flammable or explosive materials occurs. For the purpose of this section, rooms or spaces that are not part of the

living space of a dwelling unit and that communicate directly with a private garage through openings shall be considered to be part of the private garage.

703.1.1 Natural ventilation. Indoor locations intended for hydrogen-generating or refueling operations shall communicate with the outdoors in accordance with Sections 703.1.1.1 through 703.1.1.2. The minimum cross-sectional dimension of air openings shall be 3 inches (76 mm). Where ducts are used, they shall be of the same cross-sectional area as the free area of the openings to which they connect. In such locations, equipment and appliances having an ignition source shall be located such that the source of ignition is not less than 12 inches (305 mm) below the ceiling.

703.1.1.1 Two openings. Two permanent openings, one located entirely within 12 inches (305 mm) of the ceiling of the garage, and one located entirely within 12 inches (305 mm) of the floor of the garage, shall be provided in the same exterior wall. The openings shall communicate directly with the outdoors. Each opening shall directly communicate with the outdoors horizontally, and have a minimum free area of 1/2 square foot per 1,000 cubic feet (1 m²/610 m³) of garage volume.

703.1.1.2 Louvers and grilles. In calculating the free area required by Section 703.1.1.1, the required size of openings shall be based on the net free area of each opening. If the free area through a design of louver or grille is known, it shall be used in calculating the size opening required to provide the free area specified. If the design and free area are not known, it shall be assumed that wood louvers will have 25-percent free area and metal louvers and grilles will have 75-percent free area. Louvers and grilles shall be fixed in the open position.

703.1.2 Mechanical ventilation. Indoor locations intended for hydrogen-generating or refueling operations shall be ventilated in accordance with Section 502.15 of the *International Mechanical Code*.

703.1.3 Specially engineered installations. As an alternative to the provisions of Section 703.1.1 and 703.1.2, the necessary supply of air for ventilation and dilution of flammable gases shall be provided by an approved engineered system.

703.2 Containers, cylinders and tanks. Compressed gas containers, cylinders and tanks shall comply with Chapters 30 and 35 of the *International Fire Code*.

703.2.1 Limitations for indoor storage and use. Flammable gas cylinders in occupancies regulated by the *International Residential Code* shall not exceed 250 cubic feet (7.1 m³) at normal temperature and pressure (NTP).

703.2.2 Design and construction. Compressed gas containers, cylinders and tanks shall be designed, constructed and tested in accordance with the Chapter 27 of the *International Fire Code*, *ASME Boiler and Pressure Vessel Code* (Section VIII) or DOTn 49 CFR, Parts 100-180.

703.3 Pressure relief devices. Pressure relief devices shall be provided in accordance with Sections 703.3.1 through 703.3.8. Pressure relief devices shall be sized and selected in accordance with CGA S-1.1, CGA S-1.2 and CGA S-1.3.

703.3.1 Valves between pressure relief devices and containers. Valves including shutoffs, check valves and other mechanical restrictions shall not be installed between the pressure relief device and container being protected by the relief device.

Exception: A locked-open shutoff valve on containers equipped with multiple pressure-relief device installations where the arrangement of the valves provides the full required flow through the minimum number of required relief devices at all times.

703.3.2 Installation. Valves and other mechanical restrictions shall not be located between the pressure relief device and the point of release to the atmosphere.

703.3.3 Containers. Containers shall be provided with pressure relief devices in accordance with the ASME *Boiler and Pressure Vessel Code* (Section VIII), DOTn 49 CFR, Parts 100-180 and Section 703.3.7.

703.3.4 Vessels other than containers. Vessels other than containers shall be protected with pressure relief devices in accordance with the ASME *Boiler and Pressure Vessel Code* (Section VIII), or DOTn 49 CFR, Parts 100-180.

703.3.5 Sizing. Pressure relief devices shall be sized in accordance with the specifications to which the container was fabricated. The relief device shall be sized to prevent the maximum design pressure of the container or system from being exceeded.

703.3.6 Protection. Pressure relief devices and any associated vent piping shall be designed, installed and located so that their operation will not be affected by water or other debris accumulating inside the vent or obstructing the vent.

703.3.7 Access. Pressure relief devices shall be located such that they are provided with ready access for inspection and repair.

703.3.8 Configuration. Pressure relief devices shall be arranged to discharge unobstructed in accordance with Section 2209 of the *International Fire Code*. Discharge shall be directed to the outdoors in such a manner as to prevent impingement of escaping gas on personnel, containers, equipment and adjacent structures and to prevent introduction of escaping gas into enclosed spaces. The discharge shall not terminate under eaves or canopies.

Exception: This section shall not apply to DOTn-specified containers with an internal volume of 2 cubic feet (0.057 m³) or less.

703.4 Venting. Relief device vents shall be terminated in an approved location in accordance with Section 2209 of the *International Fire Code*.

703.5 Security. Compressed gas containers, cylinders, tanks and systems shall be secured against accidental dislodgement in accordance with Chapter 30 of the *International Fire Code*.

703.6 Electrical wiring and equipment. Electrical wiring and equipment shall comply with the ~~ICC~~ Seattle *Electrical Code*.

SECTION 704 (IFGC) PIPING, USE AND HANDLING

704.1 Applicability. Use and handling of containers, cylinders, tanks and hydrogen gas systems shall comply with this section. Gaseous hydrogen systems, equipment and machinery shall be listed or approved.

704.1.1 Controls. Compressed gas system controls shall be designed to prevent materials from entering or leaving process or reaction systems at other than the intended time, rate or path. Automatic controls shall be designed to be fail safe in accordance with accepted engineering practice.

704.1.2 Piping systems. Piping, tubing, valves and fittings conveying gaseous hydrogen shall be designed and installed in accordance with Sections 704.1.2.1 through 704.1.2.5, Chapter 27 of the *International Fire Code*, and ASME B31.3. Cast-iron pipe, valves and fittings shall not be used.

704.1.2.1 Sizing. Gaseous hydrogen piping shall be sized in accordance with approved engineering methods.

704.1.2.2 Identification. Piping used to convey gaseous hydrogen shall be identified and marked "HYDROGEN," at intervals not exceeding 10 feet (3048 mm). Letters of such marking shall be in a color other than the color of the piping. Piping shall be identified a minimum of one time in each room or space through which it extends.

704.1.2.3 Piping design and construction. Piping systems shall be Type 304, Type 304L or Type 316 stainless steel tubing listed or approved for hydrogen service and the use intended through the full range of pressure and temperature to which they will be subjected. Piping systems shall be designed and constructed to provide allowance for expansion, contraction, vibration, settlement and fire exposure.

704.1.2.3.1 Prohibited locations. Piping shall not be installed in or through a circulating air duct, clothes chute, chimney or gas vent, ventilating duct, dumbwaiter or elevator shaft.

704.1.2.3.2 Piping in solid partitions and walls. Concealed piping shall not be located in solid partitions and solid walls, except where installed in a ventilated chase or casing.

704.1.2.3.3 Piping in concealed locations. Portions of a piping system installed in concealed locations shall not have unions, tubing fittings, right or left couplings, bushings, compression couplings and swing joints made by combinations of fittings.

Exceptions:

1. Tubing joined by brazing.
2. Fittings listed for use in concealed locations.

704.1.2.3.4 Piping through foundation wall. Underground piping shall not penetrate the outer foundation or basement wall of a building.

704.1.2.3.5 Protection against physical damage. In concealed locations, where piping other than stainless steel piping, stainless steel tubing or black steel is installed through holes or notches in wood studs, joists, rafters or similar members less than 1 inch (25 mm) from the nearest edge of the member, the pipe shall be protected by shield plates. Shield plates shall be a minimum of $\frac{1}{16}$ -inch-thick (1.6 mm) steel, shall cover the area of the pipe where the member is notched or bored, and shall extend a minimum of 4 inches (102 mm) above sole plates, below top plates and to each side of a stud, joist or rafter.

704.1.2.3.6 Piping in solid floors. Piping in solid floors shall be laid in channels in the floor and covered in a manner that will allow access to the piping with a minimum amount of damage to the building. Where such piping is subject to exposure to excessive moisture or corrosive substances, the piping shall be protected in an approved manner. As an alternative to installation in channels, the piping shall be installed in a casing of Schedule 40 steel, wrought-iron, PVC or ABS pipe with tightly sealed ends and joints and the casing shall be ventilated to the outdoors. Both ends of such casing shall extend not less than 2 inches (51 mm) beyond the point where the pipe emerges from the floor.

704.1.2.3.7 Piping outdoors. Piping installed above ground, outdoors, shall be securely supported and located where it will be protected from physical damage. Piping passing through an exterior wall of a building shall be encased in a protective pipe sleeve. The annular space between the piping and the sleeve shall be sealed from the inside such that the sleeve is ventilated to the outdoors. Where passing through an exterior wall of a building, the piping shall also be protected against corrosion by coating or wrapping with an inert material. Below-ground piping shall be protected against corrosion.

704.1.2.3.8 Settlement. Piping passing through interior concrete or masonry walls shall be protected against differential settlement.

704.1.2.4 Joints. Joints on piping and tubing shall be listed for hydrogen service, inclusive of welded, brazed, flared, socket, slip or compression fittings. Gaskets and sealants shall be listed for hydrogen service. Threaded or flanged connections shall not be used in areas other than hydrogen cutoff rooms or outdoors.

704.1.2.5 Valves and piping components. Valves, regulators and piping components shall be listed or approved for hydrogen service, shall be provided with access and shall be designed and constructed to withstand the maximum pressure to which such components will be subjected.

704.1.2.5.1 Shutoff valves on storage containers and tanks. Shutoff valves shall be provided on all storage container and tank connections except for pressure relief devices. Shutoff valves shall be provided with ready access.

704.2 Upright use. Compressed gas containers, cylinders and tanks, except those with a water volume less than 1.3 gallons (5 L) and those designed for use in a horizontal position, shall be used in an upright position with the valve end up. An upright position shall include conditions where the container, cylinder or tank axis is inclined as much as 45 degrees (0.79 rad) from the vertical.

704.3 Material-specific regulations. In addition to the requirements of this section, indoor and outdoor use of hydrogen compressed gas shall comply with the material-specific provisions of Chapters 30 and 35 of the *International Fire Code*.

704.4 Handling. The handling of compressed gas containers, cylinders and tanks shall comply with Chapter 27 of the *International Fire Code*.

SECTION 705 (IFGC) TESTING OF HYDROGEN PIPING SYSTEMS

705.1 General. Prior to acceptance and initial operation, all piping installations shall be inspected and pressure tested to determine that the materials, design fabrication and installation practices comply with the requirements of this code.

705.2 Inspections. Inspection shall consist of a visual examination of the entire piping system installation and a pressure test, prior to system operation. Engineered systems shall be designed using approved engineering methods and the inspection procedures of ASME B31.3, and such inspections shall be verified by the code official.

705.3 Pressure test. The test pressure shall be not less than $1\frac{1}{2}$ times the proposed maximum working pressure, but not less than 5 pounds per square inch gauge (psig) (34.5 kPa gauge), irrespective of the design pressure. Where the test pressure exceeds 125 psig (862 kPa gauge), the test pressure shall not exceed a value that produces hoop stress in the piping greater than 50 percent of the specified minimum yield strength of the pipe. Testing of engineered systems shall utilize the testing procedures of ASME B31.3 provided that test duration and gauge accuracy are included in the procedures as specified in Sections 705.3.1 and 705.3.2.

705.3.1 Test duration. The test duration shall not be less than $\frac{1}{2}$ hour for each 500 cubic feet (14.2 m³) of pipe volume. For piping systems having a volume of more than 24,000 cubic feet (680 m³), the duration of the test shall not be required to exceed 24 hours.

705.3.2 Test gauges. Gauges used for testing shall be as follows:

1. Tests requiring a pressure of 10 pounds per square inch (psi) (68.95 kPa) or less shall utilize a testing gauge having increments of 0.10 psi (.6895 kPa) or less.
2. Tests requiring a pressure of greater than 10 psi (68.95 kPa) but less than or equal to 100 psi (689.5 kPa) shall

utilize a testing gauge having increments of 1 psi (6.895 kPa) or less.

3. Tests requiring a pressure test greater than 100 psi (689.5 kPa) shall utilize a testing gauge having increments of 2 psi (13.79 kPa) or less.

Exception: Measuring devices having an equivalent level of accuracy shall be permitted where approved by the design engineer and the code official.

705.4 Detection of leaks and defects. The piping system shall withstand the test pressure specified without showing any evidence of leakage or other defects.

705.4.1 Corrections. Where leakage or other defects are located, the affected portion of the piping system shall be repaired and retested.

SECTION 706 (IFGC)

LOCATION OF GASEOUS HYDROGEN SYSTEMS

706.1 General. This section shall govern the location and installation of gaseous hydrogen systems.

Exceptions:

1. Dispensing equipment need not be separated from canopies that are constructed in accordance with the *International Building Code* and in a manner that prevents the accumulation of hydrogen gas.
2. Gaseous hydrogen systems located in a separate building designed and constructed in accordance with the *International Building Code* and NFPA 50A.
3. Gaseous hydrogen systems located inside a building in a hydrogen cutoff room designed and constructed in accordance with Section 706.3 and the *International Building Code*.
4. Gaseous hydrogen systems located inside a building not in a hydrogen cutoff room where the gaseous hydrogen system is listed and labeled for indoor installation and installed in accordance with the manufacturer's installation instructions.
5. Stationary fuel-cell power plants in accordance with Section 633.

706.2 Location on property. Gaseous hydrogen systems shall be located in accordance with Chapter 22 of the *International Fire Code*.

706.3 Hydrogen cutoff rooms. Hydrogen cutoff rooms shall be designed and constructed in accordance with Sections 706.3.1 through 706.3.8 and the *International Building Code*.

706.3.1 Design and construction. Interior building openings shall be equipped with self-closing devices. Interior openings shall be electronically interlocked with the gaseous hydrogen system to prevent operation of the system when such openings are ajar or the room shall be provided with a mechanical exhaust ventilation system designed with a capture velocity at the opening of not less than 60 feet per minute (0.3048 m/s). Operable windows are prohibited in interior walls.

706.3.2 Ventilation. Cutoff rooms shall be provided with mechanical ventilation in accordance with the applicable

provisions for repair garages in Chapter 5 of the *International Mechanical Code*.

Exception: This section shall not apply to rooms provided with ventilation systems meeting the requirements of Section 706.3.1.

706.3.3 Gas detection system. Hydrogen cutoff rooms shall be provided with an approved flammable gas-detection system in accordance with Sections 706.3.3.1 through 706.3.3.3.

706.3.3.1 System design. The flammable gas-detection system shall be listed for use with hydrogen and any other flammable gases used in the room. The gas detection system shall be designed to activate when the level of flammable gas exceeds 25 percent of the lower flammability limit (LFL) for the gas or mixtures present at anticipated temperature and pressure.

706.3.3.2 Operation. Activation of the gas detection system shall result in all of the following:

1. Initiation of distinct audible and visual alarm signals both inside and outside of the cutoff room.
2. Activation of the mechanical ventilation system.

706.3.3.3 Failure of the gas detection system. Failure of the gas detection system shall result in activation of the mechanical ventilation system, cessation of hydrogen generation and the sounding of a trouble signal in an approved location.

706.3.4 Ignition source control. Open flames, flame-producing devices and other sources of ignition shall be controlled in accordance with Chapter 35 of the *International Fire Code*.

706.3.5 Explosion control. Explosion control shall be provided in accordance with Chapter 9 of the *International Fire Code*.

706.3.6 Standby power. Mechanical ventilation and gas detection systems shall be connected to a standby power system in accordance with Chapter 27 of the *International Fire Code*.

706.3.7 Smoking. Smoking shall be prohibited in hydrogen cutoff rooms. "No Smoking" signs shall be provided at all entrances to hydrogen cutoff rooms.

706.3.8 Housekeeping. The hydrogen cutoff room shall be kept free from combustible debris and storage at all times.

SECTION 707 (IFGC) OPERATION AND MAINTENANCE OF GASEOUS HYDROGEN SYSTEMS

707.1 Maintenance. Gaseous hydrogen systems and detection devices shall be maintained in accordance with the *International Fire Code* and the manufacturer's installation instructions.

707.2 Purging. Purging of gaseous hydrogen systems shall be in accordance with Section 2211.8 of the *International Fire Code*.

**SECTION 708 (IFGC)
DESIGN OF LIQUEFIED HYDROGEN SYSTEMS
ASSOCIATED WITH HYDROGEN
VAPORIZATION OPERATIONS**

708.1 General. The design of liquefied hydrogen systems shall comply with Chapter 32 of the *International Fire Code*.

